

FORT EDWARD UNION FREE SCHOOL DISTRICT

220 BROADWAY
FORT EDWARD, NEW YORK 12828
(518) 747-4529

Daniel A. Ward
Superintendent of Schools

John Galarneau
K-12 Principal

Lead in Water Testing Notification

December 23, 2020

Dear Parents, Guardians and Staff:

On September 6, 2016 Governor Cuomo signed legislation which requires public schools in New York State to test all potable water sources for lead. The first required testing occurred in 2016, and as required by law the Fort Edward School was due for updated testing in 2020. A waiver was available to postpone the 2020 testing due to the COVID Pandemic, but the Fort Edward School chose to complete the testing on schedule as we felt it was in the best interest of the health and safety of everyone that enters our school each day.

On the morning of November 4, 2020 a total of 128 sources of water were collected and sent for analysis at the Capital Region Environmental Laboratory, which is certified by the New York State Department of Health (NYSDOH). The school obtained results on December 3, 2020, of the 128 sources tested, 9 sources or 7% were found to be in excess of the Environmental Protection Agency (EPA) and New York State Department of Health Action Level for schools.

The maximum contamination level (MCL) set by the EPA and NYSDOH is 15 parts per billion. The exact locations of each water source that was tested as well as the 9 outlets that were found in exceedance can be found on our school website. Outlets that tested with lead levels above the 15 parts per billion standard were removed from service, unless needed for handwashing. In that case, a sign was posted at the outlet indicating that the sink is not to be used for drinking and should be used for handwashing only. Outlets that tested below the MCL remain in service with no restrictions. The school will work to determine the source of lead in each of the outlets that tested above the MCL and remediate as necessary. Once these have been remediated, the Fort Edward Union School District will resample water from the identified outlets.

According to the EPA, lead in drinking water is rarely the sole cause of lead poisoning. Additionally, human skin does not absorb lead in water so even if water contains lead over the state's action level, it is safe for hand washing, cleaning, or science applications. For more information about lead levels and drinking water, visit the EPA's website <https://www.epa.gov/ground-water-and-drinking-water>.

While we know that this information may cause you some concern, we are taking the necessary steps to address the situation and confirm the safety of water throughout the school. There is nothing that we take more seriously than the well-being of our students and staff. We will provide more information when it becomes available, please contact me if you have any questions.

Respectfully,



Daniel A. Ward
Superintendent of Schools
Fort Edward Union Free School District

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00065
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-0-KF-1

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.004	0.015		mg/L	SM3113B	MN	11/13/2020

Qualifiers Key:


- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
 Lead Technical Director Environmental Laboratory
 and contact person
 If you have questions, please call.
 (518) 949-2020

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00066
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-0-KF-2

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.007	0.015		mg/L	SM3113B	MN	11/13/2020

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
 Lead Technical Director Environmental Laboratory
 and contact person
 If you have questions, please call.
 (518) 949-2020

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00067
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-0-KF-3

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.003	0.015		mg/L	SM3113B	MN	11/13/2020

Qualifiers Key:


- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.
(518) 949-2020

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00068
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-0-KF-4

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.004	0.015		mg/L	SM3113B	MN	11/13/2020

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.
(518) 949-2020

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00069
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-0-KF-5

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.004	0.015		mg/L	SM3113B	MN	11/13/2020

Qualifiers Key:


- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.
(518) 949-2020

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00070
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-0-KF-6

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.005	0.015		mg/L	SM3113B	MN	11/13/2020

Qualifiers Key:


- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
 Lead Technical Director Environmental Laboratory
 and contact person
 If you have questions, please call.
 (518) 949-2020

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00071
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-0-WC-7

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.003	0.015		mg/L	SM3113B	MN	11/13/2020

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
 Lead Technical Director Environmental Laboratory
 and contact person
 If you have questions, please call.
 (518) 949-2020

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00072
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-0-WC-8

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.003	0.015		mg/L	SM3113B	MN	11/13/2020

Qualifiers Key:


- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
 Lead Technical Director Environmental Laboratory
 and contact person
 If you have questions, please call.
 (518) 949-2020

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: **BB00073**
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-0-BF-9

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No Field Residual Chlorine:

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	11/13/2020

Qualifiers Key:


- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.
(518) 949-2020

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00074
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-1-WC-10

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	11/13/2020

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.
(518) 949-2020

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00075
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-1-WC-11

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	11/16/2020

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
 Lead Technical Director Environmental Laboratory
 and contact person
 If you have questions, please call.
 (518) 949-2020

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00076
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-1-BF-13

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	11/16/2020

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.
(518) 949-2020

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00077
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-1-BF-14

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.005	0.015		mg/L	SM3113B	MN	11/16/2020

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.
(518) 949-2020

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00078
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-1-CF-15

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.001	0.015		mg/L	SM3113B	MN	11/16/2020

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
 Lead Technical Director Environmental Laboratory
 and contact person
 If you have questions, please call.
 (518) 949-2020

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00079
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-1-DW-16

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	11/16/2020

Qualifiers Key:


- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
 Lead Technical Director Environmental Laboratory
 and contact person
 If you have questions, please call.
 (518) 949-2020

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00080
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-1-CF-17

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.002	0.015		mg/L	SM3113B	MN	11/16/2020

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
 Lead Technical Director Environmental Laboratory
 and contact person
 If you have questions, please call.
 (518) 949-2020

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00081
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-1-DW-18

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.001	0.015		mg/L	SM3113B	MN	11/16/2020

Qualifiers Key:


- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.
(518) 949-2020

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00082
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-1-CF-19

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.001	0.015		mg/L	SM3113B	MN	11/16/2020

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
 Lead Technical Director Environmental Laboratory
 and contact person
 If you have questions, please call.
 (518) 949-2020

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: **BB00083**
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-1-DW-20

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No Field Residual Chlorine:

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	11/16/2020

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.

Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.
(518) 949-2020

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00084
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-1-CF-21

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.002	0.015		mg/L	SM3113B	MN	11/16/2020

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.
(518) 949-2020

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00085
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-1-DW-22

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.002	0.015		mg/L	SM3113B	MN	11/16/2020

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
 Lead Technical Director Environmental Laboratory
 and contact person
 If you have questions, please call.
 (518) 949-2020

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00086
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-1-CF-23

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.075	0.015	X	mg/L	SM3113B	MN	11/16/2020

Qualifiers Key:


- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.
(518) 949-2020

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00087
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-1-DW-24

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.087	0.015	X	mg/L	SM3113B	MN	11/16/2020

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.
(518) 949-2020

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00088
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-1-CF-25

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.002	0.015		mg/L	SM3113B	MN	11/16/2020

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.
(518) 949-2020

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1

Sample ID: **BB00089**
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-1-DW-26

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No Field Residual Chlorine:

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.001	0.015		mg/L	SM3113B	MN	11/16/2020

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.
(518) 949-2020

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00090
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-1-CF-27

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.001	0.015		mg/L	SM3113B	MN	11/16/2020

Qualifiers Key:


- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
 Lead Technical Director Environmental Laboratory
 and contact person
 If you have questions, please call.
 (518) 949-2020

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00091
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-1-DW-28

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.001	0.015		mg/L	SM3113B	MN	11/16/2020

Qualifiers Key:


- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
 Lead Technical Director Environmental Laboratory
 and contact person
 If you have questions, please call.
 (518) 949-2020

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00092
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-1-CF-29

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.002	0.015		mg/L	SM3113B	MN	11/16/2020

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.
(518) 949-2020

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00093
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-1-DW-30

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.008	0.015		mg/L	SM3113B	MN	11/16/2020

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.
(518) 949-2020

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00094
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-1-CF-31

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.001	0.015		mg/L	SM3113B	MN	11/16/2020

Qualifiers Key:


- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
 Lead Technical Director Environmental Laboratory
 and contact person
 If you have questions, please call.
 (518) 949-2020

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: **BB00095**
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-1-DW-32

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No Field Residual Chlorine:

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.002	0.015		mg/L	SM3113B	MN	11/16/2020

Qualifiers Key:


- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.
(518) 949-2020

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00096
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-1-CF-33

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	11/16/2020

Qualifiers Key:


- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
 Lead Technical Director Environmental Laboratory
 and contact person
 If you have questions, please call.
 (518) 949-2020

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00097
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-1-DW-34

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.006	0.015		mg/L	SM3113B	MN	11/16/2020

Qualifiers Key:


- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.
(518) 949-2020

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: **BB00098**
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-1-KF-35

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No Field Residual Chlorine:

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	11/16/2020

Qualifiers Key:


- | | | |
|---|--|-----------------------------|
| X Exceeds maximum contamination limit | R Duplication outside acceptance limits | H Hold time exceeded |
| T Temperature outside specifications | A Sample contained air bubble or headspace | B Analyte detected in blank |
| C(+/-) CCV outside acceptable limits | Z Analysis is not state-certified | G Incorrect bottle received |
| S(+/-) Lab control sample outside acceptance limits | M(+/-) Matrix spike recovery outside acceptance limits | P Sample preserved at lab |
- (+ Result may be biased high / - Result may be biased low)

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.
(518) 949-2020

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00099
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-1-BF-36

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.001	0.015		mg/L	SM3113B	MN	11/16/2020

Qualifiers Key:


- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.
(518) 949-2020

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00100
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-1-BF-37

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	11/16/2020

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
 Lead Technical Director Environmental Laboratory
 and contact person
 If you have questions, please call.
 (518) 949-2020

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00101
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-1-BF-38

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	11/16/2020

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
 Lead Technical Director Environmental Laboratory
 and contact person
 If you have questions, please call.
 (518) 949-2020

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00102
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-1-BF-39

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	11/16/2020

Qualifiers Key:


- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
 Lead Technical Director Environmental Laboratory
 and contact person
 If you have questions, please call.
 (518) 949-2020

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00103
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-1-BF-40

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	11/16/2020

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.
(518) 949-2020

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00104
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-1-WC-41

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	11/16/2020

Qualifiers Key:


- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.
(518) 949-2020

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: **BB00105**
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-1-WC-42

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No Field Residual Chlorine:

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	11/16/2020

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.

Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.
(518) 949-2020

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00106
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-1-WC-43

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	11/16/2020

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
 Lead Technical Director Environmental Laboratory
 and contact person
 If you have questions, please call.
 (518) 949-2020

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00107
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-1-BF-44

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	11/16/2020

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
 Lead Technical Director Environmental Laboratory
 and contact person
 If you have questions, please call.
 (518) 949-2020

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00108
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-1-BF-45

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	11/16/2020

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.
(518) 949-2020

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00109
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-1-BF-46

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	11/16/2020

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
 Lead Technical Director Environmental Laboratory
 and contact person
 If you have questions, please call.
 (518) 949-2020

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00110
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-1-BF-47

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	11/16/2020

Qualifiers Key:


- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
 Lead Technical Director Environmental Laboratory
 and contact person
 If you have questions, please call.
 (518) 949-2020

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00111
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-1-BF-48

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.002	0.015		mg/L	SM3113B	MN	11/16/2020

Qualifiers Key:


- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.
(518) 949-2020

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00112
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-1-BF-49

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.002	0.015		mg/L	SM3113B	MN	11/16/2020

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
 Lead Technical Director Environmental Laboratory
 and contact person
 If you have questions, please call.
 (518) 949-2020

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00113
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-2-CF-50

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.002	0.015		mg/L	SM3113B	MN	11/16/2020

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.
(518) 949-2020

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00114
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-2-CF-51

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.003	0.015		mg/L	SM3113B	MN	11/16/2020

Qualifiers Key:


- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
 Lead Technical Director Environmental Laboratory
 and contact person
 If you have questions, please call.
 (518) 949-2020

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00115
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-2-CF-52

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.001	0.015		mg/L	SM3113B	MN	11/16/2020

Qualifiers Key:


- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.
(518) 949-2020

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00116
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-2-CF-53

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.002	0.015		mg/L	SM3113B	MN	11/16/2020

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.
(518) 949-2020

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00117
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-2-CF-54

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.002	0.015		mg/L	SM3113B	MN	11/17/2020

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.
(518) 949-2020

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00118
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-2-CF-55

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.002	0.015		mg/L	SM3113B	MN	11/17/2020

Qualifiers Key:


- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.
(518) 949-2020

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00119
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-2-CF-56

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.001	0.015		mg/L	SM3113B	MN	11/17/2020

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
 Lead Technical Director Environmental Laboratory
 and contact person
 If you have questions, please call.
 (518) 949-2020

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1

Sample ID: **BB00120**
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-2-CF-57

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No Field Residual Chlorine:

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.001	0.015		mg/L	SM3113B	MN	11/17/2020

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.

Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.
(518) 949-2020

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00121
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-2-BF-58

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	11/17/2020

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
 Lead Technical Director Environmental Laboratory
 and contact person
 If you have questions, please call.
 (518) 949-2020

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00122
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-2-BF-59

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.001	0.015		mg/L	SM3113B	MN	11/17/2020

Qualifiers Key:


- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
 Lead Technical Director Environmental Laboratory
 and contact person
 If you have questions, please call.
 (518) 949-2020

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00123
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-2-BF-60

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	11/17/2020

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
 Lead Technical Director Environmental Laboratory
 and contact person
 If you have questions, please call.
 (518) 949-2020

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00124
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-2-BF-61

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	11/17/2020

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
 Lead Technical Director Environmental Laboratory
 and contact person
 If you have questions, please call.
 (518) 949-2020

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00125
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-2-WC-62

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	11/17/2020

Qualifiers Key:


- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
 Lead Technical Director Environmental Laboratory
 and contact person
 If you have questions, please call.
 (518) 949-2020

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00126
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-2-WC-63

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No Field Residual Chlorine:

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	11/17/2020

Qualifiers Key:


- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.
(518) 949-2020

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00127
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-2-WC-64

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	11/17/2020

Qualifiers Key:


- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.
(518) 949-2020

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: **BB00128**
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-2-BF-65

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No Field Residual Chlorine:

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.002	0.015		mg/L	SM3113B	MN	11/17/2020

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.

Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.
(518) 949-2020

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00129
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-2-BF-66

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.001	0.015		mg/L	SM3113B	MN	11/17/2020

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.
(518) 949-2020

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00130
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-2-BF-67

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	11/17/2020

Qualifiers Key:


- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
 Lead Technical Director Environmental Laboratory
 and contact person
 If you have questions, please call.
 (518) 949-2020

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00131
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-2-BF-68

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	11/17/2020

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
 Lead Technical Director Environmental Laboratory
 and contact person
 If you have questions, please call.
 (518) 949-2020

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00132
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-2-CF-69

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.002	0.015		mg/L	SM3113B	MN	11/17/2020

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.
(518) 949-2020

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00133
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-2-CF-70

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.002	0.015		mg/L	SM3113B	MN	11/17/2020

Qualifiers Key:


- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
 Lead Technical Director Environmental Laboratory
 and contact person
 If you have questions, please call.
 (518) 949-2020

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00134
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-2-CF-71

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.002	0.015		mg/L	SM3113B	MN	11/17/2020

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.
(518) 949-2020

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00135
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-2-CF-72

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.001	0.015		mg/L	SM3113B	MN	11/17/2020

Qualifiers Key:


- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.
(518) 949-2020

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00136
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-2-BF-73

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.004	0.015		mg/L	SM3113B	MN	11/17/2020

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.
(518) 949-2020

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00137
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-2-BF-74

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.002	0.015		mg/L	SM3113B	MN	11/17/2020

Qualifiers Key:


- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
 Lead Technical Director Environmental Laboratory
 and contact person
 If you have questions, please call.
 (518) 949-2020

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00138
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-2-KF-75

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.001	0.015		mg/L	SM3113B	MN	11/17/2020

Qualifiers Key:


- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
 Lead Technical Director Environmental Laboratory
 and contact person
 If you have questions, please call.
 (518) 949-2020

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00139
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-2-NS-76

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.006	0.015		mg/L	SM3113B	MN	11/17/2020

Qualifiers Key:


- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
 Lead Technical Director Environmental Laboratory
 and contact person
 If you have questions, please call.
 (518) 949-2020

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00140
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-2-BF-77

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.005	0.015		mg/L	SM3113B	MN	11/17/2020

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
 Lead Technical Director Environmental Laboratory
 and contact person
 If you have questions, please call.
 (518) 949-2020

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00141
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-2-BF-78

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.005	0.015		mg/L	SM3113B	MN	11/17/2020

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
 Lead Technical Director Environmental Laboratory
 and contact person
 If you have questions, please call.
 (518) 949-2020

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00142
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-2-WC-79

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	11/17/2020

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
 Lead Technical Director Environmental Laboratory
 and contact person
 If you have questions, please call.
 (518) 949-2020

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00143
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-1-WC-80

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	11/17/2020

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
 Lead Technical Director Environmental Laboratory
 and contact person
 If you have questions, please call.
 (518) 949-2020

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00144
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-1-BF-81

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.009	0.015		mg/L	SM3113B	MN	11/17/2020

Qualifiers Key:

- | | | |
|---|--|-----------------------------|
| X Exceeds maximum contamination limit | R Duplication outside acceptance limits | H Hold time exceeded |
| T Temperature outside specifications | A Sample contained air bubble or headspace | B Analyte detected in blank |
| C(+/-) CCV outside acceptable limits | Z Analysis is not state-certified | G Incorrect bottle received |
| S(+/-) Lab control sample outside acceptance limits | M(+/-) Matrix spike recovery outside acceptance limits | P Sample preserved at lab |
- (+ Result may be biased high / - Result may be biased low)

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
 Lead Technical Director Environmental Laboratory
 and contact person
 If you have questions, please call.
 (518) 949-2020

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1

Sample ID: **BB00145**
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-1-BF-82

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No Field Residual Chlorine:

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.007	0.015		mg/L	SM3113B	MN	11/17/2020

Qualifiers Key:

- | | | |
|---|--|-----------------------------|
| X Exceeds maximum contamination limit | R Duplication outside acceptance limits | H Hold time exceeded |
| T Temperature outside specifications | A Sample contained air bubble or headspace | B Analyte detected in blank |
| C(+/-) CCV outside acceptable limits | Z Analysis is not state-certified | G Incorrect bottle received |
| S(+/-) Lab control sample outside acceptance limits | M(+/-) Matrix spike recovery outside acceptance limits | P Sample preserved at lab |
- (+ Result may be biased high / - Result may be biased low)

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.
(518) 949-2020

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00146
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-1-WC-83

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.002	0.015		mg/L	SM3113B	MN	11/17/2020

Qualifiers Key:


- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
 Lead Technical Director Environmental Laboratory
 and contact person
 If you have questions, please call.
 (518) 949-2020

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00147
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-1-BF-84

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.008	0.015		mg/L	SM3113B	MN	11/17/2020

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
 Lead Technical Director Environmental Laboratory
 and contact person
 If you have questions, please call.
 (518) 949-2020

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00148
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-1-BF-85

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.022	0.015	X	mg/L	SM3113B	MN	11/17/2020

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
 Lead Technical Director Environmental Laboratory
 and contact person
 If you have questions, please call.
 (518) 949-2020

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00149
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-1-BF-86

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.039	0.015	X	mg/L	SM3113B	MN	11/17/2020

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
 Lead Technical Director Environmental Laboratory
 and contact person
 If you have questions, please call.
 (518) 949-2020

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00150
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-1-BF-88

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.006	0.015		mg/L	SM3113B	MN	11/17/2020

Qualifiers Key:


- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
 Lead Technical Director Environmental Laboratory
 and contact person
 If you have questions, please call.
 (518) 949-2020

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00151
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-1-NS-89

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.003	0.015		mg/L	SM3113B	MN	11/17/2020

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.
(518) 949-2020

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00152
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-1-WC-90

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.001	0.015		mg/L	SM3113B	MN	11/17/2020

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
 Lead Technical Director Environmental Laboratory
 and contact person
 If you have questions, please call.
 (518) 949-2020

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00153
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-1-WC-91

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	11/17/2020

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
 Lead Technical Director Environmental Laboratory
 and contact person
 If you have questions, please call.
 (518) 949-2020

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00154
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-1-BF-92

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.003	0.015		mg/L	SM3113B	MN	11/17/2020

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
 Lead Technical Director Environmental Laboratory
 and contact person
 If you have questions, please call.
 (518) 949-2020

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00155
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-1-BF-93

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.002	0.015		mg/L	SM3113B	MN	11/17/2020

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
 Lead Technical Director Environmental Laboratory
 and contact person
 If you have questions, please call.
 (518) 949-2020

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00156
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-1-WC-94

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.008	0.015		mg/L	SM3113B	MN	11/17/2020

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.
(518) 949-2020

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00157
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-1-BF-95

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.005	0.015		mg/L	SM3113B	MN	11/17/2020

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.
(518) 949-2020

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1

Sample ID: **BB00158**
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-2-BF-96

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No Field Residual Chlorine:

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.005	0.015		mg/L	SM3113B	MN	11/17/2020

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.
(518) 949-2020

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00159
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-2-BF-97

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.004	0.015		mg/L	SM3113B	MN	11/17/2020

Qualifiers Key:


- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
 Lead Technical Director Environmental Laboratory
 and contact person
 If you have questions, please call.
 (518) 949-2020

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00160
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-2-KF-98

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.002	0.015		mg/L	SM3113B	MN	11/17/2020

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
 Lead Technical Director Environmental Laboratory
 and contact person
 If you have questions, please call.
 (518) 949-2020

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00161
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-1-BF-99

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.001	0.015		mg/L	SM3113B	MN	11/17/2020

Qualifiers Key:


- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
 Lead Technical Director Environmental Laboratory
 and contact person
 If you have questions, please call.
 (518) 949-2020

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00162
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-1-BF-100

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.002	0.015		mg/L	SM3113B	MN	11/17/2020

Qualifiers Key:


- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
 Lead Technical Director Environmental Laboratory
 and contact person
 If you have questions, please call.
 (518) 949-2020

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00163
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-1-BF-102

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	11/17/2020

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.
(518) 949-2020

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00164
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-3-WC-106

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.001	0.015		mg/L	SM3113B	MN	11/17/2020

Qualifiers Key:


- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
 Lead Technical Director Environmental Laboratory
 and contact person
 If you have questions, please call.
 (518) 949-2020

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00165
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-3-WC-107

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.001	0.015		mg/L	SM3113B	MN	11/17/2020

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
 Lead Technical Director Environmental Laboratory
 and contact person
 If you have questions, please call.
 (518) 949-2020

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00166
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-1-BF-108

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.002	0.015		mg/L	SM3113B	MN	11/17/2020

Qualifiers Key:


- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
 Lead Technical Director Environmental Laboratory
 and contact person
 If you have questions, please call.
 (518) 949-2020

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00167
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-1-BF-109

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.002	0.015		mg/L	SM3113B	MN	11/17/2020

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
 Lead Technical Director Environmental Laboratory
 and contact person
 If you have questions, please call.
 (518) 949-2020

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00168
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-1-WC-110

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.001	0.015		mg/L	SM3113B	MN	11/17/2020

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
 Lead Technical Director Environmental Laboratory
 and contact person
 If you have questions, please call.
 (518) 949-2020

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00169
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-1-WC-111

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.001	0.015		mg/L	SM3113B	MN	11/17/2020

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.
(518) 949-2020

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00170
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-1-WC-112

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.008	0.015		mg/L	SM3113B	MN	11/17/2020

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.
(518) 949-2020

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00171
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-2-WC-113

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.002	0.015		mg/L	SM3113B	MN	11/17/2020

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
 Lead Technical Director Environmental Laboratory
 and contact person
 If you have questions, please call.
 (518) 949-2020

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00172
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-2-WC-114

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	11/17/2020

Qualifiers Key:


- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
 Lead Technical Director Environmental Laboratory
 and contact person
 If you have questions, please call.
 (518) 949-2020

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1

Sample ID: **BB00173**
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-2-WC-115

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No Field Residual Chlorine:

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.001	0.015		mg/L	SM3113B	MN	11/17/2020

Qualifiers Key:

- | | | |
|---|--|-----------------------------|
| X Exceeds maximum contamination limit | R Duplication outside acceptance limits | H Hold time exceeded |
| T Temperature outside specifications | A Sample contained air bubble or headspace | B Analyte detected in blank |
| C(+/-) CCV outside acceptable limits | Z Analysis is not state-certified | G Incorrect bottle received |
| S(+/-) Lab control sample outside acceptance limits | M(+/-) Matrix spike recovery outside acceptance limits | P Sample preserved at lab |
- (+ Result may be biased high / - Result may be biased low)

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.
(518) 949-2020

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: **BB00174**
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-2-BF-116

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No Field Residual Chlorine:

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.002	0.015		mg/L	SM3113B	MN	11/17/2020

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.
(518) 949-2020

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1

Sample ID: **BB00175**
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-2-BF-117

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No Field Residual Chlorine:

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.002	0.015		mg/L	SM3113B	MN	11/17/2020

Qualifiers Key:

- | | | |
|---|--|-----------------------------|
| X Exceeds maximum contamination limit | R Duplication outside acceptance limits | H Hold time exceeded |
| T Temperature outside specifications | A Sample contained air bubble or headspace | B Analyte detected in blank |
| C(+/-) CCV outside acceptable limits | Z Analysis is not state-certified | G Incorrect bottle received |
| S(+/-) Lab control sample outside acceptance limits | M(+/-) Matrix spike recovery outside acceptance limits | P Sample preserved at lab |
- (+ Result may be biased high / - Result may be biased low)

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.
(518) 949-2020

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00176
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-2-KF-119

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.004	0.015		mg/L	SM3113B	MN	11/17/2020

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.
(518) 949-2020

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00177
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-2-BF-120

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.001	0.015		mg/L	SM3113B	MN	11/17/2020

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
 Lead Technical Director Environmental Laboratory
 and contact person
 If you have questions, please call.
 (518) 949-2020

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00178
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-2-BF-121

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.002	0.015		mg/L	SM3113B	MN	11/17/2020

Qualifiers Key:


- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.
(518) 949-2020

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00179
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-2-KF-122

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.014	0.015		mg/L	SM3113B	MN	11/17/2020

Qualifiers Key:


- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
 Lead Technical Director Environmental Laboratory
 and contact person
 If you have questions, please call.
 (518) 949-2020

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00180
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-2-KF-123

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.039	0.015	X	mg/L	SM3113B	MN	11/17/2020

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.
(518) 949-2020

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00181
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-2-KF-124

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No Field Residual Chlorine:

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.019	0.015	X	mg/L	SM3113B	MN	11/17/2020

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.

Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.
(518) 949-2020

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00182
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-2-KF-125

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.004	0.015		mg/L	SM3113B	MN	11/17/2020

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.
(518) 949-2020

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00183
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-2-KF-126

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.037	0.015	X	mg/L	SM3113B	MN	11/17/2020

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
 Lead Technical Director Environmental Laboratory
 and contact person
 If you have questions, please call.
 (518) 949-2020

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00184
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-2-KF-127

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.024	0.015	X	mg/L	SM3113B	MN	11/17/2020

Qualifiers Key:


- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
 Lead Technical Director Environmental Laboratory
 and contact person
 If you have questions, please call.
 (518) 949-2020

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 12/2/2020 Page 1 of 1
Sample ID: BB00185
Date Received: 11/09/2020
Time Received: 12:31
Date Finalized: 11/18/2020
PO Number:
Your Ref:

Customer: Needham Risk Management Resource Group
Owner: Fort Edward UFSD
Sample Loc: Fort Edward UFSD
Sample Pt: FE-2-KF-128

Collect Date: 11/04/2020
Collect Time: 00:00
Collected by: NEEDHAM
Receipt Temp: 20 C See Note 1

Water Source:
Chlorinated: No **Field Residual Chlorine:**

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.036	0.015	X	mg/L	SM3113B	MN	11/17/2020

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptable limits
- S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins
 Lead Technical Director Environmental Laboratory
 and contact person
 If you have questions, please call.
 (518) 949-2020

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

School Name:		Fort Edward Union Free School District							
Lab ELAP ID# 10350		Analysis Method:			EPA 200.8 REV 5.4				
Lab ID	School Building	Sample ID#	Collection Date	Sample Location	Outlet Description	Initial/Post	Results µg/L (ppb)	Lab Report Receipt Date	Action Taken
Capital Region Environmental Laboratory	FEUFSD	FE-0-KF-1	11/4/2020	Kitchen hand sink	Kitchen faucet	Initial	0.004	11/18/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-0-KF-2	11/4/2020	Kitchen prep sink	Kitchen faucet	Initial	0.007	11/18/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-0-KF-3	11/4/2020	Kitchen 2-bay next to hand sink	Kitchen faucet	Initial	0.003	11/18/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-0-KF-4	11/4/2020	Kitchen steam kettle	Kitchen faucet	Initial	0.004	11/18/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-0-KF-5	11/4/2020	Kitchen 2-bay in wash area	Kitchen faucet	Initial	0.004	11/18/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-0-KF-6	11/4/2020	Kitchen sprayer in wash area	Kitchen faucet	Initial	0.005	11/18/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-0-WC-7	11/4/2020	Bottle filler in cafeteria	Bottle filler	Initial	0.003	11/18/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-0-WC-8	11/4/2020	Drinking fountain in cafeteria	Water fountain	Initial	0.008	11/18/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-0-BF-9	11/4/2020	Bathroom sink outside cafeteria	Bathroom faucet	Initial	<0.001	11/18/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-1-WC-10	11/4/2020	Bottle filler next to computer lab	Bottle filler	Initial	<0.001	11/18/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-1-WC-11	11/4/2020	Drinking fountain next to computer lab (left)	Water fountain	Initial	<0.001	11/18/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-1-WC-12	11/4/2020	Drinking fountain next to computer lab (right)	Water fountain	No Sample			Collection Scheduled
Capital Region Environmental Laboratory	FEUFSD	FE-1-BF-13	11/4/2020	Women's bathroom Trophy hallway	Bathroom faucet	Initial	<0.001	11/18/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-1-BF-14	11/4/2020	Men's bathroom Trophy hallway	Bathroom faucet	Initial	0.005	11/18/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-1-CF-15	11/4/2020	112	Classroom faucet	Initial	0.001	11/18/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-1-DW-16	11/4/2020	112	Water fountain	Initial	<0.001	11/18/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-1-CF-17	11/4/2020	114	Classroom faucet	Initial	0.002	11/18/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-1-DW-18	11/4/2020	114	Water fountain	Initial	0.001	11/18/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-1-CF-19	11/4/2020	116	Classroom faucet	Initial	0.001	11/18/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-1-DW-20	11/4/2020	116	Water fountain	Initial	<0.001	11/18/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-1-CF-21	11/4/2020	118	Classroom faucet	Initial	0.002	11/18/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-1-DW-22	11/4/2020	118	Water fountain	Initial	0.002	11/18/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-1-CF-23	11/4/2020	120	Classroom faucet	Initial	0.075	11/18/2020	Marked DO NOT DRINK, RETEST Scheduled
Capital Region Environmental Laboratory	FEUFSD	FE-1-DW-24	11/4/2020	120	Water fountain	Initial	0.087	11/18/2020	Marked OUT OF SERVICE, RETEST Scheduled

Capital Region Environmental Laboratory	FEUFSD	FE-1-CF-25	11/4/2020	122	Classroom faucet	Initial	0.002	11/18/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-1-DW-26	11/4/2020	122	Water fountain	Initial	0.001	11/18/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-1-CF-27	11/4/2020	124	Classroom faucet	Initial	0.001	11/18/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-1-DW-28	11/4/2020	124	Water fountain	Initial	0.001	11/18/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-1-CF-29	11/4/2020	135	Classroom faucet	Initial	0.002	11/18/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-1-DW-30	11/4/2020	135	Water fountain	Initial	0.008	11/18/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-1-CF-31	11/4/2020	133	Classroom faucet	Initial	0.001	11/18/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-1-DW-32	11/4/2020	133	Water fountain	Initial	0.002	11/18/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-1-CF-33	11/4/2020	131	Classroom faucet	Initial	<0.001	11/18/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-1-DW-34	11/4/2020	131	Water fountain	Initial	0.006	11/18/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-1-KF-35	11/4/2020	Elementary faculty lounge	Kitchen faucet	Initial	<0.001	12/2/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-1-BF-36	11/4/2020	Elementary faculty lounge bathroom sink	Bathroom faucet	Initial	0.001	11/18/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-1-BF-37	11/4/2020	Girl's room next to elementary faculty lounge (far left)	Bathroom faucet	Initial	<0.001	11/18/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-1-BF-38	11/4/2020	Girl's room next to elementary faculty lounge (left)	Bathroom faucet	Initial	<0.001	11/18/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-1-BF-39	11/4/2020	Girl's room next to elementary faculty lounge (right)	Bathroom faucet	Initial	<0.001	11/18/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-1-BF-40	11/4/2020	Girl's room next to elementary faculty lounge (far right)	Bathroom faucet	Initial	<0.001	11/18/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-1-WC-41	11/4/2020	Elementary bottle filler	Bottle filler	Initial	<0.001	11/18/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-1-WC-42	11/4/2020	Elementary drinking fountain (left)	Water fountain	Initial	<0.001	11/18/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-1-WC-43	11/4/2020	Elementary drinking fountain (right)	Water fountain	Initial	<0.001	11/18/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-1-BF-44	11/4/2020	Boy's room next to elementary faculty lounge (far left)	Bathroom faucet	Initial	<0.001	11/18/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-1-BF-45	11/4/2020	Boy's room next to elementary faculty lounge (left)	Bathroom faucet	Initial	<0.001	11/18/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-1-BF-46	11/4/2020	Boy's room next to elementary faculty lounge (right)	Bathroom faucet	Initial	<0.001	11/18/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-1-BF-47	11/4/2020	Boy's room next to elementary faculty lounge (far right)	Bathroom faucet	Initial	<0.001	11/18/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-1-BF-48	11/4/2020	119	Bathroom faucet	Initial	0.002	12/2/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-1-BF-49	11/4/2020	107 - CSE	Bathroom faucet	Initial	0.002	11/18/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-2-CF-50	11/4/2020	222	Classroom faucet	Initial	0.002	11/18/2020	NA

Capital Region Environmental Laboratory	FEUFSD	FE-2-CF-51	11/4/2020	219	Classroom faucet	Initial	0.003	11/18/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-2-CF-52	11/4/2020	220	Classroom faucet	Initial	0.001	11/18/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-2-CF-53	11/4/2020	217	Classroom faucet	Initial	0.002	12/2/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-2-CF-54	11/4/2020	215	Classroom faucet	Initial	0.002	12/2/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-2-CF-55	11/4/2020	218	Classroom faucet	Initial	0.002	12/2/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-2-CF-56	11/4/2020	213	Classroom faucet	Initial	0.001	12/2/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-2-CF-57	11/4/2020	216	Classroom faucet	Initial	0.001	12/2/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-2-BF-58	11/4/2020	Girl's room upstairs elementary (far left)	Bathroom faucet	Initial	<0.001	12/2/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-2-BF-59	11/4/2020	Girl's room upstairs elementary (left)	Bathroom faucet	Initial	0.001	12/2/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-2-BF-60	11/4/2020	Girl's room upstairs elementary (right)	Bathroom faucet	Initial	<0.001	12/2/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-2-BF-61	11/4/2020	Girl's room upstairs elementary (far right)	Bathroom faucet	Initial	<0.001	12/2/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-2-WC-62	11/4/2020	Bottle filler upstairs elementary	Bottle filler	Initial	<0.001	12/2/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-2-WC-63	11/4/2020	Drinking fountain upstairs elem. (left)	Water fountain	Initial	<0.001	12/2/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-2-WC-64	11/4/2020	Drinking fountain upstairs elem. (right)	Water fountain	Initial	<0.001	12/2/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-2-BF-65	11/4/2020	Boy's room upstairs elementary (far left)	Bathroom faucet	Initial	0.002	12/2/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-2-BF-66	11/4/2020	Boy's room upstairs elementary (left)	Bathroom faucet	Initial	0.001	12/2/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-2-BF-67	11/4/2020	Boy's room upstairs elementary (right)	Bathroom faucet	Initial	<0.001	12/2/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-2-BF-68	11/4/2020	Boy's room upstairs elementary (far right')	Bathroom faucet	Initial	<0.001	12/2/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-2-CF-69	11/4/2020	209	Classroom faucet	Initial	0.002	12/2/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-2-CF-70	11/4/2020	214	Classroom faucet	Initial	0.002	12/2/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-2-CF-71	11/4/2020	212	Classroom faucet	Initial	0.002	12/2/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-2-CF-72	11/4/2020	210	Classroom faucet	Initial	0.001	12/2/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-2-BF-73	11/4/2020	203 (Men's bathroom)	Bathroom faucet	Initial	0.004	12/2/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-2-BF-74	11/4/2020	201 (Women's bathroom)	Bathroom faucet	Initial	0.002	12/2/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-2-KF-75	11/4/2020	202B - Library	Kitchen faucet	Initial	0.001	12/2/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-2-NS-76	11/4/2020	Nurse's sink	Nurse faucet	Initial	0.006	12/2/2020	NA

Capital Region Environmental Laboratory	FEUFSD	FE-2-BF-77	11/4/2020	Nurse's bathroom sink	Bathroom faucet	Initial	0.005	12/2/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-2-BF-78	11/4/2020	Maintenance room bathroom sink	Bathroom faucet	Initial	0.005	12/2/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-2-WC-79	11/4/2020	Bottle filler by scoreboard	Bottle filler	Initial	<0.001	12/2/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-1-WC-80	11/4/2020	Drinking fountain by scoreboard	Water fountain	Initial	<0.001	12/2/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-1-BF-81	11/4/2020	Boy's locker room - left sink	Bathroom faucet	Initial	0.009	12/2/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-1-BF-82	11/4/2020	Boy's locker room - right sink	Bathroom faucet	Initial	0.007	12/2/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-1-WC-83	11/4/2020	Boy's locker room drinking fountain	Water fountain	Initial	0.002	12/2/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-1-BF-84	11/4/2020	Boy's coach office bathroom sink	Bathroom faucet	Initial	0.008	12/2/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-1-BF-85	11/4/2020	Girl's locker room - right sink	Bathroom faucet	Initial	0.022	12/2/2020	Marked DO NOT DRINK, RETEST Scheduled
Capital Region Environmental Laboratory	FEUFSD	FE-1-BF-86	11/4/2020	Girl's locker room - left sink	Bathroom faucet	Initial	0.039	12/2/2020	Marked DO NOT DRINK, RETEST Scheduled
Capital Region Environmental Laboratory	FEUFSD	FE-1-WC-87	11/4/2020	Girl's locker room - drinking fountain	Water fountain	No Sample			Collection Scheduled
Capital Region Environmental Laboratory	FEUFSD	FE-1-BF-88	11/4/2020	Girl's coach office bathroom sink	Bathroom faucet	Initial	0.006	12/2/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-1-NS-89	11/4/2020	Registrar nurse sink	Nurse faucet	Initial	0.003	12/2/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-1-WC-90	11/4/2020	Drinking fountain (left) BOCES hallway	Water fountain	Initial	0.001	12/2/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-1-WC-91	11/4/2020	Drinking fountain (right) BOCES hallway	Water fountain	Initial	<0.001	12/2/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-1-BF-92	11/4/2020	Adult bathroom BOCES hallway	Bathroom faucet	Initial	0.003	12/2/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-1-BF-93	11/4/2020	Kid's changing room BOCES hallway	Bathroom faucet	Initial	0.002	12/2/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-1-WC-94	11/4/2020	Drinking fountain outside district office	Water fountain	Initial	0.008	12/2/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-1-BF-95	11/4/2020	District office bathroom sink	Bathroom faucet	Initial	0.005	12/2/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-2-BF-96	11/4/2020	Superintendent's wing Bathroom sink	Bathroom faucet	Initial	0.005	12/2/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-2-BF-97	11/4/2020	Superintendent's wing Kitchen bathroom sink	Bathroom faucet	Initial	0.004	12/2/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-2-KF-98	11/4/2020	Superintendent's wing Kitchen sink	Kitchen faucet	Initial	0.002	12/2/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-1-BF-99	11/4/2020	108 - Boy's room (left)	Bathroom faucet	Initial	0.001	12/2/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-1-BF-100	11/4/2020	108 - Boy's room (right)	Bathroom faucet	Initial	0.002	12/2/2020	NA
Capital Region Environmental Laboratory	FEUFSD	FE-1-WC-101	11/4/2020	Water cooler next to 108	Water fountain	No Sample			Collection Scheduled
Capital Region Environmental Laboratory	FEUFSD	FE-1-BF-102	11/4/2020	Single bathroom across from Rm 101	Bathroom faucet	Initial	<0.001	12/2/2020	NA

Capital Region Environmental Laboratory	FEUFSD	FE-1-CF-103	11/4/2020	Room 101 - left	Classroom faucet	No Sample				Collection Scheduled
Capital Region Environmental Laboratory	FEUFSD	FE-1-CF-104	11/4/2020	Room 101 - middle	Classroom faucet	No Sample				Collection Scheduled
Capital Region Environmental Laboratory	FEUFSD	FE-1-CF-105	11/4/2020	Room 101 - right	Classroom faucet	No Sample				Collection Scheduled
Capital Region Environmental Laboratory	FEUFSD	FE-3-WC-106	11/4/2020	3rd floor bottle filler	Bottle filler	Initial	0.001	12/2/2020		NA
Capital Region Environmental Laboratory	FEUFSD	FE-3-WC-107	11/4/2020	3rd floor water fountain	Water fountain	Initial	0.001	12/2/2020		NA
Capital Region Environmental Laboratory	FEUFSD	FE-1-BF-108	11/4/2020	110 - Girl's room (left)	Bathroom faucet	Initial	0.002	12/2/2020		NA
Capital Region Environmental Laboratory	FEUFSD	FE-1-BF-109	11/4/2020	110 - Girl's room (right)	Bathroom faucet	Initial	0.002	12/2/2020		NA
Capital Region Environmental Laboratory	FEUFSD	FE-1-WC-110	11/4/2020	Bottle filler next to Rm 110	Bottle filler	Initial	0.001	12/2/2020		NA
Capital Region Environmental Laboratory	FEUFSD	FE-1-WC-111	11/4/2020	Drinking fountain next to Rm 110	Water fountain	Initial	0.001	12/2/2020		NA
Capital Region Environmental Laboratory	FEUFSD	FE-1-WC-112	11/4/2020	Drinking fountain next to Rm 116	Water fountain	Initial	0.008	12/2/2020		NA
Capital Region Environmental Laboratory	FEUFSD	FE-2-WC-113	11/4/2020	Drinking fountain next to Rm 214	Water fountain	Initial	0.002	12/2/2020		NA
Capital Region Environmental Laboratory	FEUFSD	FE-2-WC-114	11/4/2020	Bottle filler across from Rm 204	Bottle filler	Initial	<0.001	12/2/2020		NA
Capital Region Environmental Laboratory	FEUFSD	FE-2-WC-115	11/4/2020	Drinking fountain across from Rm 204	Water fountain	Initial	0.001	12/2/2020		NA
Capital Region Environmental Laboratory	FEUFSD	FE-2-BF-116	11/4/2020	High school 2nd floor girl's bathroom across from Rm 204 (left)	Bathroom faucet	Initial	0.002	12/2/2020		NA
Capital Region Environmental Laboratory	FEUFSD	FE-2-BF-117	11/4/2020	High school 2nd floor girl's bathroom across from Rm 204 (right)	Bathroom faucet	Initial	0.002	12/2/2020		NA
Capital Region Environmental Laboratory	FEUFSD	FE-2-WC-118	11/4/2020	Drinking fountain across from Rm 201	Water fountain	No Sample				Collection Scheduled
Capital Region Environmental Laboratory	FEUFSD	FE-2-KF-119	11/4/2020	High school faculty lounge sink	Kitchen faucet	Initial	0.004	12/2/2020		NA
Capital Region Environmental Laboratory	FEUFSD	FE-2-BF-120	11/4/2020	High school 2nd floor boy's bathroom (Left)	Bathroom faucet	Initial	0.001	12/2/2020		NA
Capital Region Environmental Laboratory	FEUFSD	FE-2-BF-121	11/4/2020	High school 2nd floor boy's bathroom (Right)	Bathroom faucet	Initial	0.002	12/2/2020		NA
Capital Region Environmental Laboratory	FEUFSD	FE-2-KF-122	11/4/2020	Home & Careers sprayer #1	Kitchen faucet	Initial	0.014	12/2/2020		NA
Capital Region Environmental Laboratory	FEUFSD	FE-2-KF-123	11/4/2020	Home & Careers sink #1	Kitchen faucet	Initial	0.039	12/2/2020		Marked DO NOT DRINK, RETEST Scheduled
Capital Region Environmental Laboratory	FEUFSD	FE-2-KF-124	11/4/2020	Home & Careers sink #2	Kitchen faucet	Initial	0.019	12/2/2020		Marked DO NOT DRINK, RETEST Scheduled
Capital Region Environmental Laboratory	FEUFSD	FE-2-KF-125	11/4/2020	Home & Careers sprayer #2	Kitchen faucet	Initial	0.004	12/2/2020		NA
Capital Region Environmental Laboratory	FEUFSD	FE-2-KF-126	11/4/2020	Home & Careers sink #3	Kitchen faucet	Initial	0.037	12/2/2020		Marked DO NOT DRINK, RETEST Scheduled
Capital Region Environmental Laboratory	FEUFSD	FE-2-KF-127	11/4/2020	Home & Careers sprayer #3	Kitchen faucet	Initial	0.024	12/2/2020		Marked DO NOT DRINK, RETEST Scheduled
Capital Region Environmental Laboratory	FEUFSD	FE-2-KF-128	11/4/2020	Home & Careers sink #4	Kitchen faucet	Initial	0.036	12/2/2020		Marked DO NOT DRINK, RETEST Scheduled